

## G99 Grid Code Compliance Statement for IntelliNeo 6000 and IntelliNeo 5500

The **IntelliNeo 6000** and **IntelliNeo 5500** controllers comply with the G99 Grid Code for connection to UK distribution networks. Both controllers integrate essential protection and control functions, including over-voltage, under-voltage, and frequency protection, ensuring safe operation in parallel with the grid.

Both devices utilize the same grid code module as the IG1000, IM1010, and IS2000 controllers, allowing for self-declaration of compliance without external testing.

For further details, please contact our certification department.

In Prague, September 30, 2024

Marek Novotný  
R&D Director

ComAp a.s.  
U Uranie 1612/14a,  
170 00 Prague,  
Czech Republic  
[comap-control.com](http://comap-control.com)

A handwritten signature in blue ink, appearing to read 'Marek Novotný', located in the bottom right corner of the document.